

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252025
Address: 1432 SE SILO ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, July 22, 2025

Corrective Action Required:

1	Misc	- Address anchor bolts at garage sill plate breaks too close to edge. Anchor bolts To be not closer than 7x the diameter of bolt from end and not more than 12" away
		- No sill plate under stud on West side of exterior corner wall of basement north/ west corner

Comments: