

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235208
Address: 2911 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Khanh Nguyen	Partial	Thursday, June 12, 2025

Corrective Action Required:

1 LOWER LEVEL

Corrective Action Required:

2 FIRST FLOOR

Corrective Action Required:

3 SECOND FLOOR

Corrective Action Required:

4 THIRD FLOOR -Tub&shower walls-screw OK
 -Kitchen/corridor walls-screw OK

Corrective Action Required:

5 STAIR TOWER 1 **THIS IS NORTH STAIR A**

Lower floor:

-stair side 2nd layer

1st floor:

-stair side 2nd layer

2nd floor:

-stair side 2nd layer

3rd floor:

-stair side 2nd layer

Corrective Action Required:

6

STAIR TOWER 2

****THIS IS SOUTH STAIR A****

Lower floor:

-stair side 2nd layer

1st floor:

-stair side 2nd layer

2nd floor:

-stair side 2nd layer

3rd floor:

-stair side 2nd layer

Corrective Action Required:

7

STAIR TOWER 3

****THIS IS REAR STAIR B****

Lower floor:

-elevator/stair wall-stair side 2nd layer

Corrective Action Required:

8

ELEVATOR 1

-4th floor, dwelling side 1st layer

Corrective Action Required:

4

FOURTH FLOOR

-Tub&shower walls-screw OK

-Kitchen/corridor wall-screw OK

Comments: