

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20243187  
Address: 100 NE ALURA WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection</b>	Nick Scott	Failed	Tuesday, July 22, 2025

Informational:

1 Misc

5-16-25 DP. I am sure they have more work to complete, but we need to keep up on erosion control around the stock piles and non-vegetated area whether or not that is the erosion mats or silt fence as we have a multiple days of rain coming this next week.

7-22-25 NS Site visited and it appears that jobsite needs grass seed on bare spots and on lot 2 they need Erosion control put up and the road needs to be cleaned up.

**Comments:**