

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20242774  
Address: 1000 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Robb Popp	Partial	Wednesday, July 23, 2025

**Corrective Action Required:**

1	Misc	-30' Conduit at NW corner of building -20' Conduit at NE corner of building -Secondary conduits from transformer to NE of building  - Conduit across West end of wash bays - Conduits from middle of wash bays turn up into equipment room - Conduit from CT cab to transformers on East end
---	------	--

**Comments:**