



2/17/75



FIRE PROTECTION SYSTEMS INC.

"We are your Advantage"

**404B N.W. 11th Street
Blue Springs, MO. 64015
Tel. (816) 224-3400**

Advantage Fire Protection
404B NW 11th Street
Blue Springs, MO 64015
816-224-3400

Job Name : LS Management Hangar
Drawing : 2751 NE Douglas Road
Location : Lee's Summit, Missouri 64064
Remote Area : AREA 1
Contract : J-2492
Data File : area 1 7-13-25.WXF

Hydraulic Design Information Sheet

Name - LS Management Hangar Date - 7/13/25
Location - Lee's Summit, Missouri 64064
Building - 2751 NE Douglas Road System No. - AREA 1
Contractor - Contract No. - J-2492
Calculated By - Drawing No. - 1
Construction: () Combustible (X) Non-Combustible Ceiling Height - 27-0
Occupancy - DEFUELED AIRCRAFT HANGAR

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 (X) 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve
S Other PER NFPA 409 .17/5000
T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 5000	System Type	Sprinkler/Nozzle
	Density	- .17	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 130	() Dry	Model QR
E	Elevation at Highest Outlet	- 125.208	() Deluge	Size 3/4"
S	Hose Allowance - Inside	-	() Preaction	K-Factor 8.0
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.286
G	Hose Allowance - Outside	- 500		

N Note

Calculation Flow Required - 1496.34 Press Required - 55.562 TEST
Summary C-Factor Used: 120 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 2/10/25		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 92	@ Press -	
R	Residual Press - 65	Elev. -	Well
	Flow - 2025		Proof Flow
S	Elevation - 95		

U Location -

P
L Source of Information -
Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf
O			
R	Flue Spacing	Clearance:Storage to Ceiling	
A	Longitudinal	Transverse	
G			
E	Horizontal Barriers Provided:		

Water Supply Curve

Advantage Fire Protection
LS Management Hangar


Page 2
Date 7/13/25

City Water Supply:

C1 - Static Pressure : 92
C2 - Residual Pressure: 65
C2 - Residual Flow : 2025

Demand:

D1 - Elevation : 13.083
D2 - System Flow : 996.35
D2 - System Pressure : 55.562
Hose (Demand) : 500
D3 - System Demand : 1496.35
Safety Margin : 21.010



Fittings Used Summary

Advantage Fire Protection
LS Management Hangar

Page 3
Date 7/13/25

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	9.3	11	0	0	0	0	0
Zdj	Deringer 30x DCDA II Vert	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

Advantage Fire Protection
LS Management Hangar

Page 4
Date 7/13/25

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	92.0	65	2025.0	76.573	1496.35	55.562

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
A1	117.792		12.19			
1	121.292		9.71			
2	121.917	8	9.19	24.25	0.17	130
3	122.75	8	8.67	23.55	0.17	130
4	123.583	8	8.27	23.01	0.17	130
5	124.417	8	7.91	22.5	0.17	130
6	125.208	8	7.63	22.1	0.17	130
7	125.25	8	7.81	22.36	0.17	130
8	124.458	8	8.56	23.4	0.17	130
9	123.625	8	9.6	24.79	0.17	130
10	122.75	8	11.03	26.57	0.17	130
11	121.917		12.93			
12	121.417		16.19			
A2	117.792		12.25			
13	121.292		9.76			
14	121.917	8	9.24	24.31	0.17	130
15	122.75	8	8.71	23.62	0.17	130
16	123.583	8	8.32	23.07	0.17	130
17	124.417	8	7.96	22.57	0.17	130
18	125.208	8	7.68	22.17	0.17	130
19	125.25	8	7.86	22.43	0.17	130
20	124.458	8	8.6	23.47	0.17	130
21	123.625	8	9.65	24.85	0.17	130
22	122.75	8	11.08	26.63	0.17	130
23	121.917		12.98			
24	121.417		16.25			
A3	117.792		12.47			
25	121.292		9.95			
26	121.917	8	9.42	24.55	0.17	130
27	122.75	8	8.89	23.85	0.17	130
28	123.583	8	8.48	23.3	0.17	130
29	124.417	8	8.12	22.8	0.17	130
30	125.208	8	7.84	22.4	0.17	130
31	125.25	8	8.02	22.66	0.17	130
32	124.458	8	8.77	23.69	0.17	130
33	123.625	8	9.82	25.07	0.17	130
34	122.75	8	11.26	26.85	0.17	130
35	121.917		13.18			
36	121.417		16.48			
A4	117.792		12.95			
37	121.292		10.35			
38	121.917	8	9.8	25.04	0.17	130

Flow Summary - NFPA

Advantage Fire Protection
LS Management Hangar

Page 5
Date 7/13/25

NODE ANALYSIS (cont.)

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes	
39	122.75	8	9.25	24.33	0.17	130
40	123.583	8	8.84	23.79	0.17	130
41	124.417	8	8.48	23.3	0.17	130
42	125.208	8	8.2	22.9	0.17	130
43	125.25	8	8.38	23.15	0.17	130
44	124.458	8	9.12	24.17	0.17	130
45	123.625	8	10.18	25.53	0.17	130
46	122.75	8	11.65	27.3	0.17	130
47	121.917		13.59			
48	121.417		16.96			
A5	117.792		13.78			
49	121.292		12.27			
50	121.917		12.0			
51	122.75		11.64			
52	123.583		11.28			
53	124.417		10.92			
54	125.208	8	10.57	26.01	0.17	130
55	125.25	8	10.63	26.08	0.17	130
56	124.458	8	11.23	26.8	0.17	130
57	123.625	8	12.11	27.84	0.17	130
58	122.75	8	13.39	29.28	0.17	130
59	121.917		15.16			
60	121.417		18.16			
A6	117.792		14.6			
61	121.292		14.53			
62	121.417		20.88			
A7	117.792		15.01			
63	121.292		15.15			
64	121.417		22.41			
A8	117.792		15.13			
65	121.292		15.59			
66	121.417		24.23			
B1	117.792		20.23			
B2	117.792		20.3			
B3	117.792		20.55			
B4	117.792		21.08			
B5	117.792		21.99			
B6	117.792		23.34			
B7	117.792		25.0			
B8	117.792		27.01			
TOR	117.792		32.2			
BFP	103.875		38.61			
BOR	101.0		45.42			
UG1	101.0		47.23	500.0		
TEST	95.0		55.56			

Final Calculations : Hazen-Williams

Advantage Fire Protection
LS Management Hangar

Page 6
Date 7/13/25

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A1 to 1	117.792 121.292		-67.19 -67.19	2 2.157	T X 12.307 10.461	3.583 22.768 26.351	120 -0.0366	12.191 -1.516 -0.964			
1 to 2	121.292 121.917		0.0 -67.19	2 2.157		6.875 6.875	120 -0.0367	9.711 -0.271 -0.252	Vel =	5.90	
2 to 3	121.917 122.750	8.00	24.25 -42.94	2 2.157		10.042 10.042	120 -0.0159	9.188 -0.361 -0.160	Vel =	3.77	
3 to 4	122.750 123.583	8.00	23.55 -19.39	2 2.157		10.042 10.042	120 -0.0036	8.667 -0.361 -0.036	Vel =	1.70	
4 to 5	123.583 124.417	8.00	23.01 3.62	2 2.157		10.042 10.042	120 0.0001	8.270 -0.361 0.001	Vel =	0.32	
5 to 6	124.417 125.208	8.00	22.50 26.12	2 2.157		10.042 10.042	120 0.0064	7.910 -0.343 0.064	Vel =	2.29	
6 to 7	125.208 125.250	8.00	22.10 48.22	2 2.157		10.042 10.042	120 0.0198	7.631 -0.018 0.199	Vel =	4.23	
7 to 8	125.250 124.458	8.00	22.36 70.58	2 2.157		10.042 10.042	120 0.0400	7.812 0.343 0.402	Vel =	6.20	
8 to 9	124.458 123.625	8.00	23.40 93.98	2 2.157		10.042 10.042	120 0.0681	8.557 0.361 0.684	Vel =	8.25	
9 to 10	123.625 122.750	8.00	24.79 118.77	2 2.157		10.042 10.042	120 0.1050	9.602 0.379 1.054	Vel =	10.43	
10 to 11	122.750 121.917	8.00	26.57 145.34	2 2.157		10.042 10.042	120 0.1525	11.035 0.361 1.531	Vel =	12.76	
11 to 12	121.917 121.417		0.0 145.34	2 2.157	X 10.461	9.500 10.461 19.961	120 0.1524	12.927 0.217 3.043	Vel =	12.76	
12 to B1	121.417 117.792		0.0 145.34	2 2.157	T 12.307	3.917 12.307 16.224	120 0.1525	16.187 1.570 2.474	Vel =	12.76	
B1			0.0 145.34					20.231	K Factor =	32.31	
A2 to 13	117.792 121.292		-67.55 -67.55	2 2.157	T X 12.307 10.461	3.583 22.768 26.351	120 -0.0370	12.252 -1.516 -0.974	Vel =	5.93	
13 to 14	121.292 121.917		0.0 -67.55	2 2.157		6.875 6.875	120 -0.0368	9.762 -0.271 -0.253	Vel =	5.93	
14 to 15	121.917 122.750	8.00	24.32 -43.23	2 2.157		10.042 10.042	120 -0.0162	9.238 -0.361 -0.163	Vel =	3.80	

Final Calculations : Hazen-Williams

Advantage Fire Protection
LS Management Hangar

Page 7
Date 7/13/25

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
15 to 16	122.750 123.583	8.00	23.61 -19.62	2 2.157		10.042	120 -0.0037	8.714 -0.361 -0.037		Vel = 1.72	
16 to 17	123.583 124.417	8.00	23.07 3.45	2 2.157		10.042	120 0.0001	8.316 -0.361 0.001		Vel = 0.30	
17 to 18	124.417 125.208	8.00	22.57 26.02	2 2.157		10.042	120 0.0064	7.956 -0.343 0.064		Vel = 2.28	
18 to 19	125.208 125.250	8.00	22.17 48.19	2 2.157		10.042	120 0.0198	7.677 -0.018 0.199		Vel = 4.23	
19 to 20	125.250 124.458	8.00	22.42 70.61	2 2.157		10.042	120 0.0400	7.858 0.343 0.402		Vel = 6.20	
20 to 21	124.458 123.625	8.00	23.47 94.08	2 2.157		10.042	120 0.0682	8.603 0.361 0.685		Vel = 8.26	
21 to 22	123.625 122.750	8.00	24.85 118.93	2 2.157		10.042	120 0.1052	9.649 0.379 1.056		Vel = 10.44	
22 to 23	122.750 121.917	8.00	26.63 145.56	2 2.157		10.042	120 0.1530	11.084 0.361 1.536		Vel = 12.78	
23 to 24	121.917 121.417		0.0 145.56	2 2.157	X 10.461	9.500 10.461 19.961	120 0.1529	12.981 0.217 3.052		Vel = 12.78	
24 to B2	121.417 117.792		0.0 145.56	2 2.157	T 12.307	3.917 12.307 16.224	120 0.1529	16.250 1.570 2.480		Vel = 12.78	
B2			0.0 145.56					20.300		K Factor = 32.31	
A3 to 25	117.792 121.292		-68.83 -68.83	2 2.157	T X 10.461	3.583 22.768 26.351	120 -0.0383	12.474 -1.516 -1.008		Vel = 6.04	
25 to 26	121.292 121.917		0.0 -68.83	2 2.157		6.875 6.875	120 -0.0383	9.950 -0.271 -0.263		Vel = 6.04	
26 to 27	121.917 122.750	8.00	24.55 -44.28	2 2.157		10.042	120 -0.0169	9.416 -0.361 -0.170		Vel = 3.89	
27 to 28	122.750 123.583	8.00	23.84 -20.44	2 2.157		10.042	120 -0.0040	8.885 -0.361 -0.040		Vel = 1.79	
28 to 29	123.583 124.417	8.00	23.30 2.86	2 2.157		10.042	120 0.0001	8.484 -0.361 0.001		Vel = 0.25	
29 to 30	124.417 125.208	8.00	22.81 25.67	2 2.157		10.042	120 0.0062	8.124 -0.343 0.062		Vel = 2.25	

Final Calculations : Hazen-Williams

Advantage Fire Protection
LS Management Hangar

Page 8
Date 7/13/25

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
30 to 31	125.208 125.250	8.00	22.40 48.07	2 2.157		10.042	120 0.0197	7.843 -0.018 0.198		Vel = 4.22	
31 to 32	125.250 124.458	8.00	22.66 70.73	2 2.157		10.042	120 0.0402	8.023 0.343 0.404		Vel = 6.21	
32 to 33	124.458 123.625	8.00	23.69 94.42	2 2.157		10.042	120 0.0686	8.770 0.361 0.689		Vel = 8.29	
33 to 34	123.625 122.750	8.00	25.07 119.49	2 2.157		10.042	120 0.1062	9.820 0.379 1.066		Vel = 10.49	
34 to 35	122.750 121.917	8.00	26.85 146.34	2 2.157		10.042	120 0.1544	11.265 0.361 1.550		Vel = 12.85	
35 to 36	121.917 121.417		0.0 146.34	2 2.157	X 10.461	9.500 10.461 19.961	120 0.1544	13.176 0.217 3.082		Vel = 12.85	
36 to B3	121.417 117.792		0.0 146.34	2 2.157	T 12.307	3.917 12.307 16.224	120 0.1545	16.475 1.570 2.506		Vel = 12.85	
B3			0.0 146.34					20.551		K Factor = 32.28	
A4 to 37	117.792 121.292		-71.55 -71.55	2 2.157	T X 10.461	3.583 22.768 26.351	120 -0.0411	12.949 -1.516 -1.083		Vel = 6.28	
37 to 38	121.292 121.917		0.0 -71.55	2 2.157		6.875 6.875	120 -0.0410	10.350 -0.271 -0.282		Vel = 6.28	
38 to 39	121.917 122.750	8.00	25.04 -46.51	2 2.157		10.042	120 -0.0185	9.797 -0.361 -0.186		Vel = 4.08	
39 to 40	122.750 123.583	8.00	24.33 -22.18	2 2.157		10.042	120 -0.0047	9.250 -0.361 -0.047		Vel = 1.95	
40 to 41	123.583 124.417	8.00	23.79 1.61	2 2.157		10.042	120 0	8.842 -0.361 0.0		Vel = 0.14	
41 to 42	124.417 125.208	8.00	23.30 24.91	2 2.157		10.042	120 0.0059	8.481 -0.343 0.059		Vel = 2.19	
42 to 43	125.208 125.250	8.00	22.91 47.82	2 2.157		10.042	120 0.0195	8.197 -0.018 0.196		Vel = 4.20	
43 to 44	125.250 124.458	8.00	23.15 70.97	2 2.157		10.042	120 0.0405	8.375 0.343 0.407		Vel = 6.23	
44 to 45	124.458 123.625	8.00	24.16 95.13	2 2.157		10.042	120 0.0695	9.125 0.361 0.698		Vel = 8.35	

Final Calculations : Hazen-Williams

Advantage Fire Protection
LS Management Hangar

Page 9
Date 7/13/25

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
45 to 46	123.625 122.750	8.00	25.53 120.66	2 2.157			10.042 10.042	120 0.1081	10.184 0.379 1.086		Vel = 10.59	
46 to 47	122.750 121.917	8.00	27.31 147.97	2 2.157			10.042 10.042	120 0.1575	11.649 0.361 1.582		Vel = 12.99	
47 to 48	121.917 121.417		0.0 147.97	2 2.157	X	10.461	9.500 10.461 19.961	120 0.1576	13.592 0.217 3.146		Vel = 12.99	
48 to B4	121.417 117.792		0.0 147.97	2 2.157	T	12.307	3.917 12.307 16.224	120 0.1576	16.955 1.570 2.557		Vel = 12.99	
B4			0.0 147.97						21.082		K Factor = 32.23	
A5 to 49	117.792 121.292		2.55 2.55	2 2.157	T X	12.307 10.461	3.583 22.768 26.351	120 0.0001	13.780 -1.516 0.002		Vel = 0.22	
49 to 50	121.292 121.917		0.0 2.55	2 2.157			6.875 6.875	120 0.0001	12.266 -0.271 0.001		Vel = 0.22	
50 to 51	121.917 122.750		0.0 2.55	2 2.157			10.042 10.042	120 0.0001	11.996 -0.361 0.001		Vel = 0.22	
51 to 52	122.750 123.583		0.0 2.55	2 2.157			10.042 10.042	120 0.0001	11.636 -0.361 0.001		Vel = 0.22	
52 to 53	123.583 124.417		0.0 2.55	2 2.157			10.042 10.042	120 0.0001	11.276 -0.361 0.001		Vel = 0.22	
53 to 54	124.417 125.208		0.0 2.55	2 2.157			10.042 10.042	120 0.0001	10.916 -0.343 0.001		Vel = 0.22	
54 to 55	125.208 125.250	8.00	26.02 28.57	2 2.157			10.042 10.042	120 0.0075	10.574 -0.018 0.075		Vel = 2.51	
55 to 56	125.250 124.458	8.00	26.08 54.65	2 2.157			10.042 10.042	120 0.0250	10.631 0.343 0.251		Vel = 4.80	
56 to 57	124.458 123.625	8.00	26.81 81.46	2 2.157			10.042 10.042	120 0.0522	11.225 0.361 0.524		Vel = 7.15	
57 to 58	123.625 122.750	8.00	27.84 109.3	2 2.157			10.042 10.042	120 0.0900	12.110 0.379 0.904		Vel = 9.60	
58 to 59	122.750 121.917	8.00	29.27 138.57	2 2.157			10.042 10.042	120 0.1396	13.393 0.361 1.402		Vel = 12.17	
59 to 60	121.917 121.417		0.0 138.57	2 2.157	X	10.461	9.500 10.461 19.961	120 0.1396	15.156 0.217 2.786		Vel = 12.17	

Final Calculations : Hazen-Williams

Advantage Fire Protection
LS Management Hangar

Page 10
Date 7/13/25

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
60 to B5	121.417 117.792		0.0 138.57	2 2.157	T 12.307	3.917 12.307 16.224	120 0.1396	18.159 1.570 2.265		Vel = 12.17	
B5			0.0 138.57					21.994		K Factor = 29.55	
A6 to 61	117.792 121.292		83.77 83.77	2 2.157	T X 12.307 10.461	3.583 22.768 26.351	120 0.0550	14.596 -1.516 1.450		Vel = 7.35	
61 to 62	121.292 121.417		0.0 83.77	2 2.157	X 10.461	106.000 10.461 116.461	120 0.0550	14.530 -0.054 6.406		Vel = 7.35	
62 to B6	121.417 117.792		0.0 83.77	2 2.157	T 12.307	3.917 12.307 16.224	120 0.0550	20.882 1.570 0.893		Vel = 7.35	
B6			0.0 83.77					23.345		K Factor = 17.34	
A7 to 63	117.792 121.292		89.99 89.99	2 2.157	T X 12.307 10.461	3.583 22.768 26.351	120 0.0628	15.010 -1.516 1.655		Vel = 7.90	
63 to 64	121.292 121.417		0.0 89.99	2 2.157	X 10.461	106.000 10.461 116.461	120 0.0628	15.149 -0.054 7.315		Vel = 7.90	
64 to B7	121.417 117.792		0.0 89.99	2 2.157	T 12.307	3.917 12.307 16.224	120 0.0628	22.410 1.570 1.019		Vel = 7.90	
B7			0.0 89.99					24.999		K Factor = 18.00	
A8 to 65	117.792 121.292		98.81 98.81	2 2.157	T X 12.307 10.461	3.583 22.768 26.351	120 0.0747	15.134 -1.516 1.968		Vel = 8.68	
65 to 66	121.292 121.417		0.0 98.81	2 2.157	X 10.461	106.000 10.461 116.461	120 0.0747	15.586 -0.054 8.697		Vel = 8.68	
66 to B8	121.417 117.792		0.0 98.81	2 2.157	T 12.307	3.917 12.307 16.224	120 0.0747	24.229 1.570 1.212		Vel = 8.68	
B8			0.0 98.81					27.011		K Factor = 19.01	
A1 to A2	117.792 117.792		67.19 67.19	3 3.26		12.500 12.500	120 0.0049	12.191 0.0		Vel = 2.58	
A2 to A3	117.792 117.792		67.55 134.74	3 3.26		12.500 12.500	120 0.0178	12.252 0.0		Vel = 5.18	
A3 to A4	117.792 117.792		68.83 203.57	3 3.26		12.500 12.500	120 0.0380	12.474 0.0 0.475		Vel = 7.82	

Final Calculations : Hazen-Williams

Advantage Fire Protection
LS Management Hangar

Page 11
Date 7/13/25

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A4 to A5	117.792 117.792		71.55 275.12	3 3.26		12.500 12.500	120 0.0665	12.949 0.0 0.831		Vel = 10.57	
A5 to A6	117.792 117.792		-2.56 272.56	3 3.26		12.500 12.500	120 0.0653	13.780 0.0 0.816		Vel = 10.48	
A6 to A7	117.792 117.792		-83.76 188.8	3 3.26		12.500 12.500	120 0.0331	14.596 0.0 0.414		Vel = 7.26	
A7 to A8	117.792 117.792		-89.99 98.81	3 3.26		12.500 12.500	120 0.0099	15.010 0.0 0.124		Vel = 3.80	
A8			0.0 98.81					15.134		K Factor = 25.40	
B1 to B2	117.792 117.792		145.34 145.34	4 4.26		12.500 12.500	120 0.0055	20.231 0.0 0.069		Vel = 3.27	
B2 to B3	117.792 117.792		145.57 290.91	4 4.26		12.500 12.500	120 0.0201	20.300 0.0 0.251		Vel = 6.55	
B3 to B4	117.792 117.792		146.34 437.25	4 4.26		12.500 12.500	120 0.0425	20.551 0.0 0.531		Vel = 9.84	
B4 to B5	117.792 117.792		147.96 585.21	4 4.26		12.500 12.500	120 0.0730	21.082 0.0 0.912		Vel = 13.17	
B5 to B6	117.792 117.792		138.58 723.79	4 4.26		12.500 12.500	120 0.1081	21.994 0.0 1.351		Vel = 16.29	
B6 to B7	117.792 117.792		83.76 807.55	4 4.26		12.500 12.500	120 0.1323	23.345 0.0 1.654		Vel = 18.18	
B7 to B8	117.792 117.792		89.99 897.54	4 4.26		12.500 12.500	120 0.1610	24.999 0.0 2.012		Vel = 20.20	
B8			0.0 897.54					27.011		K Factor = 172.70	
B8 to TOR	117.792 117.792		996.35 996.35	4 4.26	2V 17.907	8.667 17.907 26.574	120 0.1952	27.011 0.0 5.187		Vel = 22.43	
TOR to BFP	117.792 103.875		0.0 996.35	6 6.357		13.917 13.917	120 0.0278	32.198 6.027 0.387		Vel = 10.07	
BFP to BOR	103.875 101		0.0 996.35	6 6.357	Zdj 0.0	2.875 2.875	120 0.0278	38.612 6.727 0.080		** Fixed Loss = 5.482 Vel = 10.07	
BOR to UG1	101 101		0.0 996.35	6 5.86	T E 38.342 17.893	10.000 56.235 66.235	150 0.0273	45.419 0.0 1.811		Vel = 11.85	

Final Calculations : Hazen-Williams

Advantage Fire Protection
LS Management Hangar

Page 12
Date 7/13/25

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG1 to TEST	101 95	H500	500.00 1496.35	8 7.68	2F E T G	22.555 22.555 43.857 5.012	275.000 93.979 368.979	150 2.599 5.733		Vel = 10.36	
TEST			0.0 1496.35					55.562		K Factor = 200.74	