

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235113

Address: 2740 NE HAGAN RD, Unit:A, LEES SUMMIT, MO 640642740 NE HAGAN RD, Unit:B, LEES SUMMIT,
MO 640642740 NE HAGAN RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	Khanh Nguyen	Failed	Thursday, July 24, 2025

Corrective Action Required:

1	Misc	Gas piping not completed per plan
---	------	-----------------------------------

Corrective Action Required:

2	Misc	**Inspection failed on 5/30/25 because the gas lines to the equipments were not completed (the gas lines were capped off outside the equipment area); hence, the pressure gauges were not checked.
---	------	---

7/24/25-Gas lines from the shutoff valves in hangar down to equipments (except the gas line to the water heater) tested OK. The gas line to water heater not tested at this time

Comments: