

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20111096	Date:	March 02, 2012
Project Title:	OUR LADY OF THE PRESENTATION	Applicant:	
Location:	130 NW MURRAY RD. LEES SUMMIT, MO 64081	ADVANTAGE FIRE PROTECTION	
Type of Work:	Sprinkler Addition	404 B NORTHWEST 11TH STREET	
Occupancy Group:	E	BLUE SPRINGS, MO 64015--3638	
Description:	SCHOOL ADDITION	(816) 224-3400	
Construction Type:	Type IIB (Unprotected)		
Map Page:	195E		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

Plans received February 27, 2012.

2. Systems shall be designed to the 2006 IFC and the 2002 Edition of NFPA 13. For information only.

3. 2006 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic and flow tests.

4. Switchover from the old to new main shall require a minimal of of time and system impairment. Switchover should take place on a school holiday, weekend, or after hours.

5. The FDC shall be marked to indicate the portion of the building served.

6. Coordinate with the alarm company on the location of the exterior horn/strobe.

7. The inspectors test is not indicated on the riser detail. Confirm that a test is located on the existing system.

Verified at inspection.