

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20252080
Address: 1304 SE WINDBREAK DR, LEES SUMMIT, MO 64081

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Mitchell Schwarz	Failed - Stop Work	Thursday, July 24, 2025

Corrective Action Required

1	DCM3 ESC REQUIRED 2 DAY	07/21/25 Jamie S, Erosion control needs to be established. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	---

Corrective Action Required

2	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. EROSION CONTROL STILL NOT IN COMPLIANCE. SILT FENCE DOWN IN MULTIPLE AREAS. MAINTAIN OVERGROWN VEGETATION STOP WORK ISSUED
---	------------------------------------	---

-

Comments: