

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250074
Address: 632 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Mitchell Schwarz	Failed	Friday, July 25, 2025

Corrective Action Required:

1	Misc	-Water meter to be 14"-18" from top of meter to well ring lid -provide separation between sewer and water in trench
---	------	--

Comments: