

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20251907  
Address: 1313 SE RANCLAND ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Friday, July 25, 2025

**Corrective Action Required:**

1	Misc	Nothing done at time of inspection
		<ul style="list-style-type: none"><li>-seal dead space at owners entry</li><li>-nail all libs at intersecting wall studs 2nails per crossing intersecting wall corners</li><li>-ensure truss hangers in garage are of correct size. Plans call for lus28 on N most 4 hangers</li><li>-b2 and b4 trusses missing lateral bracing</li><li>-nail f1 trusses together to plans</li><li>-address over notched floor joist under primary bath toilet</li></ul>

**Comments:**