CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245463

Address: 2701 NE MCBAINE DR, Unit:IR, LEES SUMMIT, MO 640642701 NE MCBAINE DR, LEES SUMMIT, MO

64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Erosion Control Inspection Nick Scott Failed Friday, July 25, 2025

Informational:

1 Misc Plastic Surgun Construction

7-25-25 NS Site visited and it appears that silt fence has been knocked down

and needs to be replaced and put back up. Failed

Comments: