

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20251728  
Address: 1904 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Wes Bears	Failed	Friday, July 25, 2025

Corrective Action Required:

2	Miscellaneous	1904
	Correction	-wire needs protection within 6' of attic access in garage and second level -fire block in the basement anchor bolts and "I" beam at garage

**Comments:**