

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Friday, July 25, 2025

Corrective Action Required:

1	Misc	Pre final units only segment J 4th floor Units ok
		Sprinkler room-Seal penetrations 2400-Gfci protection required within 6' of kitchen sink 2405-Gfci protection required within 6' of kitchen sink 2407-Gfci protection required within 6' of kitchen sink

Comments: