



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20243938	Date:	July 25, 2025
Project Title:	THE VILLAGE AT DISCOVERY PET SPA	Applicant:	
Location:	1921 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 64064		
Type of Work:			ALLIANCE FIRE PROTECTION LLC
Occupancy Group:			130 W 9TH AVE STE 101
Description:	DISCOVERY PET SPA - NEW BUILDING FOR PET GROOMING AND KENNELING		KANSAS CITY, MO 64116
Construction Type:	Type VB (Unprotected)	Primary:	(913) 888-0647
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Rejected

1. Notification needs to be added to comply with IFC 2018 and NFPA 72.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.