

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20240929
Address: 2319 SW SERENA PL, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Jamie Simerly	Failed - Stop Work	Monday, July 28, 2025

Corrective Action Required

1	DCM3 ESC REQUIRED 2 DAY	04-25-25 Jamie S, Silt fence is down and there are chunks of concrete in the cul-de-sac. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 04-25-25 Jamie S, Silt fence is still down. 05-02-25 Jamie S, Silt fence is still down. 05-06-25 Jamie S, Silt fence is still down. 07/28/25 Jamie S, Silt fence needs to be established, Storm drain needs to be cleaned out in front of property. Signage has been placed for stop work order.
---	----------------------------	---

Comments: