

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20242722  
**Address:** 2303 SW SERENA PL, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Dustin Agcopra	Failed - Stop Work	Wednesday, July 30, 2025

Corrective Action Required

1	Misc	Erosion control in place at time of inspection
---	------	--

Corrective Action Required

2	DCM3 ESC REQUIRED 2 DAY	3-14-25 Dustin A, Erosion control is down in several areas , curb lines need to be cleaned. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	-------------------------	--

Corrective Action Required

3	DCM3 ESC REQUIRED 2 DAY	3-26-25 DP. Erosion control is compliant 7-28-25 Dustin A, EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 7-30-25 Dustin A, Site has not been corrected.
---	-------------------------	--

**Comments:**