

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20243024  
**Address:** 3217 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Dustin Agcopra	Failed - Stop Work	Wednesday, July 30, 2025

**Corrective Action Required**

1	DCM1 ESC REQUIRED NO FURTHER INSP	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS IN COMPLIANCE. -MAINTAIN DOWNED SILT FENCE -CLEAN TRASH AND DEBRIS FROM ROADWAY
---	--------------------------------------	--

**Corrective Action Required**

2	DCM3 ESC REQUIRED 2 DAY	04-25-25 Jamie S, Silt fence is down and needs to be repaired or reinstalled. Storm inlet protection also needs cleaned and reassessed north of lot. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 04-30-25 Jamie S, Silt fence is still down, and storm inlet has not been addressed. 05-02-25 Jamie S, Silt fence is still down, and storm inlet has not been addressed. 05-06-25 Jamie S, Silt fence is still down, and storm inlet has not been addressed.
---	----------------------------	---

**Corrective Action Required**

3	Misc	MH- called and talked with Nick.
---	------	----------------------------------

**CITY OF LEE'S SUMMIT**  
**Development Services Department**  
**220 SE Green Street**  
**Lee's Summit, MO 64063**  
**(816) 969-1200    FAX (816) 969-1201**

Drew will post property today.

Silt fence is down , needs to be reset  
Provide erosion control on side yard to downhill neighbor  
Storm inlet needs cleaned and protection put in place

**Corrective Action Required**

4        Misc

Clean up excess material on site  
Vegetation is overgrown and needs cut down

**Corrective Action Required**

5        DCM3 ESC REQUIRED 2  
          DAY

7-28-25 Dustin A, EROSION CONTROL REQUIRED. EROSION  
CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS  
DAYS.

7-30-25 Dustin A, SW has not been cleaned off . Restroom Is  
now on sidewalk.

**Comments:**