

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20243024
Address: 3217 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Failed - Stop Work	Wednesday, July 30, 2025

Corrective Action Required

1	DCM1 ESC REQUIRED NO FURTHER INSP	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS IN COMPLIANCE. -MAINTAIN DOWNED SILT FENCE -CLEAN TRASH AND DEBRIS FROM ROADWAY
---	--------------------------------------	--

Corrective Action Required

2	DCM3 ESC REQUIRED 2 DAY	04-25-25 Jamie S, Silt fence is down and needs to be repaired or reinstalled. Storm inlet protection also needs cleaned and reassessed north of lot. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 04-30-25 Jamie S, Silt fence is still down, and storm inlet has not been addressed. 05-02-25 Jamie S, Silt fence is still down, and storm inlet has not been addressed. 05-06-25 Jamie S, Silt fence is still down, and storm inlet has not been addressed.
---	----------------------------	---

Corrective Action Required

3	Misc	MH- called and talked with Nick.
---	------	----------------------------------

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Drew will post property today.

Silt fence is down , needs to be reset
Provide erosion control on side yard to downhill neighbor
Storm inlet needs cleaned and protection put in place

Corrective Action Required

4 Misc

Clean up excess material on site
Vegetation is overgrown and needs cut down

Corrective Action Required

5 DCM3 ESC REQUIRED 2
 DAY

7-28-25 Dustin A, EROSION CONTROL REQUIRED. EROSION
CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS
DAYS.

7-30-25 Dustin A, SW has not been cleaned off .No erosion
control is in place.

Comments: