

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20244922
Address: 3205 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Failed - Stop Work	Wednesday, July 30, 2025

Corrective Action Required

1	Misc	- EROSION CONTROL IN PLACE AT TIME OF INSPECTION.
---	------	---

Corrective Action Required

2	DCM3 ESC REQUIRED 2 DAY	7-28-25 Dustin A, Silt is covering sw, sw needs cleaned. There is also a buried manhole back of lot across from kline. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	---

7-30-25 Dustin A, Sw has not been cleaned off

Comments: