## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## OnlinePortal at DEVSERVICES.CITYOFLS.NET

## **Inspection Summary**

Permit #: PRCOM20243864

Address: 1901 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**In-wall Inspection** Khanh Nguyen Failed Wednesday, July 30,

2025

Corrective Action Required:

1 Misc -Install tie down per note 3

-Install hold-downs at west girder truss

-Install hangers at roof opening truss connections

**Comments:**