

July 24, 2025

**Jeremy Hull, President**  
**Hullmark Construction, LLC**  
2940 S Jackson Drive  
Independence, Missouri  
[Jhull@hullmarkllc.com](mailto:Jhull@hullmarkllc.com)

Re: **Structural Consultation and Design – “X”Bracing Relocation**  
**NAPA Store – Lee’s Summit, Missouri**


**Jeremy,**

We are pleased to confirm that relocation of “X” bracing has been installed in the center structure line of the new NAPA store. The attached drawing shows where the bracing was placed and due to the mid height placement of rods, the column was strengthened in the minor axis.


This work is completed and approved for normal use.

For the Firm,  
**LORAC Design Group, LLC**

0




**Joseph A. Towns, PE, SE, RA, AIA, NCARB, LEED AP, BD+C**  
Managing Principal  
Missouri License (Structural) #E-22017



Relocated X-Brace backed  
with  $\frac{1}{4}$ " plate in web

Existing PEMB column



New W12x14 welded to PEMB column -  
2" welds to column 24" OC alternating sides

Project: NAPA - Lee's summit X-Brace relocation

Drawn by:  
JHULL

Date:  
6/5/2025

REV #

Hullmark Construction  
20425 South Jackson Hwy  
Independence, Missouri 64057  
(816) 847-7273

