

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20232768  
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Mitchell Schwarz	Partial	Monday, July 28, 2025

Corrective Action Required:

1	Misc	Pre final units only segment J 4th floor Units ok
		Sprinkler room-Seal penetrations 2400-Gfci protection required within 6' of kitchen sink 2405-Gfci protection required within 6' of kitchen sink 2407-Gfci protection required within 6' of kitchen sink
		3rd Floor Mechanical room -seal data line/box penetrations 2311 -GFCI at balcony will not rest -bathroom receptacles to be accessible (mirror partly covering)

**Comments:**