

## **DEVELOPMENT SERVICES**

Date: Wednesday, July 30, 2025

To: JIM LONG

SCHLAGEL ASSOCIATES

From: Gene Williams, P.E.

Senior Staff Engineer

**Application Number:** PRSUBD20252429 **Application Type:** Public Infrastructure

**Application Name:** Retreat at Bailey Farms 2nd Plat

The Development Services Department received record drawing documents for this project and we have completed our review and offer the following comments listed below.

- See comments below to determine the required revisions and resubmit to the Development Services
   Department public portal located at <u>devservices.cityofls.net</u>. Digital documents shall follow the electronic plan submittal guides as stated below.
- Revised plans will be reviewed within five (10) business days of the date received.

Engineering Review - Street and Reviewed By: Gene Williams, P.E. No Comments

Storm

Engineering Review - Water Reviewed By: Gene Williams, P.E. No Comments

Water Utilities - Water Review Reviewed By: Kevin York No Comments

- 1. Sheet 3: Remove the hydrants at Sta. 0+85 and Sta. 4+76.71 on Line 10 but leave both valves near the hydrants on the water main.
- 2. Sheet 4:
- a. Remove the hydrant at Sta. 0+90 of Line 12 but leave the valve near the hydrant on the water main.
- b. The water main is too shallow on sheet 4 near Sta. 4+50.

Engineering Review - Sanitary Reviewed By: Gene Williams, P.E. No Comments

Water Utilities - Sanitary Review Reviewed By: Amanda Bagwell No Comments

- 1. It appears the water layer has been turned off. Turn on the water line layer.
- 2. I assume MH L5 extra depth was a CAD error?
- 3. It appears Line L profile is missing storm crossings and associated distances.

Please contact me if you have any questions or comments.

Sincerely,

Gene Williams, P.E. Senior Staff Engineer (816) 969-1223 Gene.Williams@cityofls.net

cc: Development Engineering Project File