

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250050
Address: 1059 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Jamie Simerly	Failed	Wednesday, July 30, 2025

Corrective Action Required:

1	Misc	- PROTECT THE FRONT OF LOT - TRIM ALL TALL VEGETATION
---	------	--

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	07/30/25 Jamie S, Erosion control needs to be reestablished. Street and downstream storm drain need to be cleaned. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	--

Comments: