

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252600
Address: 1806 NE CHERRYBARK CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Failed	Wednesday, July 30, 2025

Corrective Action Required:

1	Misc	Each fixture drain (shower and water closet) must connect individually to the vented horizontal drain; or provide individual vent for each fixture
---	------	--

Comments: