

July 24, 2025

Jeremy Hull, President
Hullmark Construction, LLC
2940 S Jackson Drive
Independence, Missouri
Jhull@hullmarkllc.com

Re: **Structural Consultation and Design – “X”Bracing Relocation**
NAPA Store – Lee’s Summit, Missouri

Jeremy,

We are pleased to confirm that relocation of “X” bracing has been installed in the center structure line of the new NAPA store. The attached drawing shows where the bracing was placed and due to the mid height placement of rods, the column was strengthened in the minor axis.

This work is completed and approved for normal use.

For the Firm,
LORAC Design Group, LLC

0



Joseph A. Towns, PE, SE, RA, AIA, NCARB, LEED AP, BD+C
Managing Principal
Missouri License (Structural) #E-22017



Relocated X-Brace backed
with $\frac{1}{4}$ " plate in web

Existing PEMB column



New W12x14 welded to PEMB column -
2" welds to column 24" OC alternating sides

Project: NAPA - Lee's summit X-Brace relocation

Drawn by:	JHULL
Date:	6/5/2025
REV #:	
Hullmark Construction 20425 South Jackson Hwy Independence, Missouri 64057 (816) 847 7273	
HMC HULLMARK CONSTRUCTION LLC	

**RELEASED FOR
CONSTRUCTION**
As Noted on Plans Review
Development Services Department
Lee's Summit, Missouri
07/30/2025

2/2