

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245644

Address: 1403 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1401 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Dustin Agcopra	Partial	Thursday, July 31, 2025

**Corrective Action Required:**

1	DCM3 ESC REQUIRED 2 DAY	7-17-25 Dustin A, Silt fence is down along 14th st, silt has washed down street onto water tower property. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 7-21-25 Dustin A, Silt fence has been taken down, mud tracked out on street , siltation has built up at bottom of hill. 7-30-25 Dustin A, Sod is laid down and contractors are cleaning up silt on water dept property
---	----------------------------	--

**Comments:**