



**RMS HEATING, COOLING, REFRIGERATION,
ELECTRICAL & PLUMBING**

1025 COUCHMAN DRIVE

KEARNEY, MO 64060

816-903-7674

FAX 816-903-7679

Tuesday, July 29, 2025


Reliable Mechanical Services, Inc.
1025 W Couchman Dr.
Kearney, MO 64060
Phone: 816-903-7674

RE:
Avital Homes
Manor of Stoney Creek; Lot #114
4421 SW Grindstone Cir.
Lee's Summit, MO 64082
Permit #RES20245637

Underslab Inspection:

Please find the following letter sent to your attention regarding the plumbing underslab installation performed at 4421 SW Grindstone Circle. RMS performed the installation to plan specification and to 2024 International Code at the above referenced address on 12/15/2024. The installation consisted of proper slope and was installed using 3" Schedule 40 PVC pipe embedded in gravel.

Sincerely,


Brandon Narron, President
Reliable Mechanical Services, Inc.