



# LEE'S SUMMIT, MISSOURI FIRE DEPARTMENT LOSS REDUCTION PROGRAM



## NOTIFICATIONS/CONTACT INFORMATION SECTION

PAGE 1

### ☐ CHANGES

<b>BUSINESS NAME</b>	SAINT LUKES EAST IT / ADMITTING REMODEL		
<b>ADDRESS</b>	100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086		
<b>OWNER/OPERATOR NAME</b>	J E DUNN CONSTRUCTION:	<b>TELEPHONE</b>	(816) 474-8600
<b>ADDRESS</b>	1001 LOCUST KANSAS CITY, MO 64106 Primary: (816) 474-8600 Cell: <NO CELL PHONE> Jeff King/ Shaw electric @ 564-2623		

## EMERGENCY CONTACT INFORMATION

NAME	TELEPHONE
1.	
2.	
3.	
4.	

## LOSS REDUCTION TYPE

<input type="checkbox"/> Occupancy	<input type="checkbox"/> Semi-Annual	<input type="checkbox"/> Annual	<input type="checkbox"/> Life Safety	<input type="checkbox"/> Sprinkler	<input type="checkbox"/> Hazardous Material Permit
<input type="checkbox"/> Complaint	<input type="checkbox"/> Explosive Storage	<input type="checkbox"/> UST	<input type="checkbox"/> Post-Incident	<input type="checkbox"/> Open Burning	<input checked="" type="checkbox"/> Other alarm sys
CLASS: I-2	Map#: 175X	PFA#:	KNOX BOX:	KNOX LOCATION:	PERMIT # PRCOM20116335

## LOSS REDUCTION NARRATIVE

### ☐ NO CORRECTIONS NOTED

### ☐ ALL CORRECTIONS COMPLETED

Last Inspection

1st Inspection 3/8/12

2nd Inspection

3rd Inspection

4th Inspection

INSPECTION	INSPECTOR	OUTCOME	DATE
<b>Alarm Test</b>	Joe Dir	Partial	Thursday, March 08, 2012
test consisted of a relocated horn strobe and 3 sets of mag door holders. all devices functioned during the alarm activation test.			
<b>Sprinkler - Hydrostatic Test</b>	Joe Dir	Not Required	Thursday, March 08, 2012
<b>Sprinkler - Flow Test</b>	Joe Dir	Not Required	Thursday, March 08, 2012
<b>DATE OF REPORT</b>	<b>INSPECTOR</b>	<b>PREVENTION FOLLOW-UP REQUIRED?</b>	<b>RESPONSIBLE SIGNATURE</b>

March 08, 2012	Joe Dir	<input type="checkbox"/> Yes <input type="checkbox"/> No	
----------------	---------	----------------------------------------------------------	--