

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250471  
Address: 2610 SW FIREFLY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Drew Fischer	Failed	Friday, August 01, 2025

**Corrective Action Required:**

1	Misc	2610 SW Firefly
		- driveway inspection needed
		- House numbers needed
		- Label sump outlet as non gfci
		- Seal all penetrations in exterior
		- Outlet needed within 10' of AC unit
		- Obtain irrigation permit

**Comments:**