



811 Cromwell Park Drive, Suite 113
Glen Burnie, Maryland 21061
410.863.1302 | onyxcreative.com

DATE: 30 July 2025

City of Lee's Summit
220 SE Green Street
Lee's Summit, MO 64063

RE: Project: PRCOM20252981

Dear Plan Reviewers:

Please find below a response to review comments generated for the above referenced project. All affected drawing sheet revisions have been clouded and designated with delta "1" clarification.

Provide verification that either the weight of new roof top equipment is less than or equal to original equipment or provide engineer's report to verify that existing roof structure will support additional load.

Response: The root top unit is existing to remain. Sheets M100 and M200 have been revised to provide clarity. On sheet M100, mechanical coded note 1 has been revised to remove the call out for a curb adaptor. On sheet M200, the curb adaptor detail has been removed and mechanical remarks have been revised.

If you should have questions or concerns, please feel free to contact me at your convenience.

Respectfully,

Shannon Bishoff

Shannon Bishoff
Interior Designer
sbishoff@onyxcreative.com