

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20231204  
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Proof Roll</b>	Dustin Agcopra	Partial	Friday, August 01, 2025

Informational:  
1 Misc 5-7-25 Dustin A, There was areas in parking lot near building 3 and club house that failed proof roll, contractor decided to pour asphalt regardless

8-1-25 Dustin A, proof roll performed on parking and drive lanes in front of building 1 and 2. There were areas that did not passed and needed attention. jake with Selby walked with me during this so he is aware of the areas and i also painted the areas in question

**Comments:**