

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244755
Address: 60 SE THOMPSON DR, Unit:B, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mitchell Schwarz	Failed	Monday, August 04, 2025

Corrective Action Required:

1 Misc

- address Mc at bath vent where connecting into box in unit 12
- secure electrical 12" of box each side unit 13,14,15,16
- missing studs at separation walls

Comments: