



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114943, Building Permit - Commercial  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Friday, March 09, 2012

Partial Correction  
1 MISC

2HR LID AT ELEVATOR SHAFT: FRAMING + 1" DESGLASS AT  
BOTTOM FACE OF FRAMING REVISED PER RFI TO BE  
PROVIDED TO JB;

**Rough Framing  
Inspection -  
Commercial**

John Borns      Partial      Friday, March 09, 2012

Partial Correction  
1 MISC

LIGHT GAUGE STEEL FRAMING AT EXTERIOR WALL AT  
LOCATIONS:

1ST LEVEL: (11) FROM (B) TO (F); (DD) FROM (0.3) TO (2.5) FULL  
HEIGHT;

2ND LEVEL: (DD) FROM (0.3) TO (7.2) FULL HEIGHT;

3RD LEVEL: PARAPET WALL NORTH SIDE TO COMPLETE

**Comments:**