

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240929
Address: 2319 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Partial	Monday, August 04, 2025

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	04-25-25 Jamie S, Silt fence is down and there are chunks of concrete in the cul-de-sac. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 04-25-25 Jamie S, Silt fence is still down. 05-02-25 Jamie S, Silt fence is still down. 05-06-25 Jamie S, Silt fence is still down. 07/28/25 Jamie S, Silt fence needs to be established, Storm drain needs to be cleaned out in front of property. Signage has been placed for stop work order. 8-4-25 Dustin A, talked with the developer. They are getting it cleaned up today . Agreed to remove order on good faith
---	----------------------------	--

Comments: