

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245916

Address: 1408 SW WINTHROP TER, LEES SUMMIT, MO 64081
1406 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Partial	Monday, August 04, 2025

Informational:

1 Misc

Erosion control and compliance at time of inspection

Corrective Action Required:

2 DCM3 ESC
REQUIRED 2 DAY

7-17-25 Dustin A, Selt fence is down and curb line needs cleaned, storm inlet needs cleaned. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.

7-21-25 Dustin A, Silt fence has been stood up , curb line and road has not be cleaned. Storm inlet still needs cleaned.

8-4-25 Dustin A, All corrections had been made, esc must be maintained throughout project.

Comments: