

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20251620
Address: 2717 SW 12TH ST, LEES SUMMIT, MO 64081

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Jamie Simerly	Failed - Stop Work	Monday, August 04, 2025

Corrective Action Required

1	DCM2 ESC DEFICIENT INSTALLATION	DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED.
---	------------------------------------	--

- Remove gravel from curb and street
- Protect front of lot.

Corrective Action Required

2	DCM3 ESC REQUIRED 2 DAY	07/30/25 Jamie S, Erosion control needs to be reestablished. Street and downstream storm drain need to be cleaned. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 08/04/25 Jamie S, Erosion control needs to be reestablished. Street and downstream storm drain need to be cleaned.
---	----------------------------	---

Comments: