

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250097  
Address: 2221 SW CROWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Drew Fischer	Failed	Monday, August 04, 2025

**Corrective Action Required:**

1	Misc	2221 SW Crown dr
		- as graded plot plan needed
		- Need house numbers
		- Sod needed and splash blocks installed
		- Sump must discharge 36" from foundation
		- Seal all exterior penetrations
		- Install floodlight at back porch

**Comments:**