

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232768
Address: 810 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Mitchell Schwarz	Partial	Monday, August 04, 2025

Corrective Action Required:

1	Misc	Pre final units only segment J -Provide GFCI protected, wet rated receptacles at rooftop -Seal penetrations at mechanical closets
	4th floor	
	Okay	
	3rd floor	
	Okay	
	2nd floor	
	Okay	
	1st floor	
	2108-Vertical grab bar to be 39"-41" aff	
	Garages and mechanical rooms not inspected	

Comments: