

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246287

Address: 1344 SW WINTHROP TER, LEES SUMMIT, MO 640811342 SW WINTHROP TER, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Wes Bears	Failed	Tuesday, August 05, 2025

Corrective Action Required:

1	Miscellaneous Correction	-electric wire cannot support vent duct in master bedroom -fire block above all windows in the basement -all soffit in basement over 4'wide needs support to floor joist
---	-----------------------------	--

Comments: