

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251888
Address: 1106 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, August 05, 2025

Corrective Action Required:

1	Misc	- Fire block top plate above egress window back side - Fire block top of fur-out wall electrical panel side (now needs gaps foamed) - Anchor bolts missing same wall - Fire block end of soffit same wall at I- beam
---	------	---

Comments: