

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245644

Address: 1403 SW WINTHROP TER, LEES SUMMIT, MO 64081
1401 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Jamie Simerly	Partial	Thursday, July 17, 2025

Informational:

1	Misc	07/11/25 Jamie S, SW is formed, gravel compacted, and slopes are in compliance with city standards. 07/17/25 Jamie S, SW slopes are compliant with city standards. ADA landing connecting 1401 and 1407 sidewalk is cracked. Builder is aware of it and is going to replace it. 8-5-25 Dustin A, SW is poured to city specs. Slopes are in compliance .
---	------	---

Comments: