

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20246440  
Address: 2769 SW 12TH ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Jamie Simerly	Failed	Tuesday, August 05, 2025

Corrective Action Required:

1	Miscellaneous Correction	- PROTECT FRONT OF LOT - TRIM ALL TALL VEGETATION
---	-----------------------------	--

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	08/05/25 Jamie S, Silt is escaping from under the sod and covering the sidewalk and street causing a safety hazard for residence around mailbox. Erosion control measures and cleanup of public surfaces are required until vegetation is established enough to stop silt for escaping on to public surfaces. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	---

**Comments:**