



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114943, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, March 12, 2012

Partial Correction
1 MISC

2HR LID AT ELEVATOR SHAFT: FRAMING + 1" DES SHIELD
SHAFT LINER AT BOTTOM FACE OF FRAMING + TWO LAYERS
OF 5/8" TYPE X DENS GLASS, WITH PERIMETER FIRE-CAULKED,
AT TOP FACE OF FRAMING PER RFI 026

Comments: