

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250691
Address: 2742 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Tuesday, August 05, 2025

Informational:
1 Misc Portal frame at garage and master bed ok to cover. Back porch ok to cover
Corrective Action Required:
2 Misc 2742 SW Hearthland
- Add 2x4 left side of bedroom 2 doorway into bath
- Fire blocking at top of post living room wall
- Add attic access to area above master

Comments: