

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251910
Address: 1131 SE RANCLAND ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Wes Bears	Failed	Tuesday, August 05, 2025

Corrective Action Required:

1	Misc	Garage portal frame nailing inspection only. Okay to cover
---	------	--

Covered patio not ready

Corrective Action Required:

2	Misc	-columns in great room addressed -columns need fastened down
---	------	---

Comments: