

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250844
Address: 2611 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Partial	Wednesday, August 06, 2025

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	07/25/25 Jamie S, Erosion control needs to be reestablished. Silt needs to be cleaned off sidewalk and storm drain. Strom drain needs to be cleaned and properly protected. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 07/29/25 Jamie S, Erosion control needs to be reestablished. Silt needs to be cleaned off sidewalk and storm drain. Strom drain needs to be cleaned and properly protected. 8/6/25 Tyler S straw waddle is replaced. Streets and curb are being cleaned. Erosion control must be maintained through out project.
---	----------------------------	--

Comments: