

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20240452
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection	Bobby Richest	Passed	Wednesday, August 06, 2025

Corrective Action Required:

1	Miscellaneous Correction	4-29-25 RH. Silt socks full and need replaced or cleaned out. No Sift fence along curbs. Mud over curbs needs cleaned. This need cleaned up immediately. Seeding will also be needed. 08/06/25 Jamie S, Erosion control is established and in compliance with city standards.
---	--------------------------	--

Comments: