CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250073

Address: 648 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Electrical Service Inspection Mitchell Schwarz Failed Wednesday, August

06, 2025

Corrective Action Required:

1 Misc -Ufer ground no connected

-service cables not landed at meter

-main disconnect not installed/panel wired as sub panel

Comments: