

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244650
Address: 1021 SW REDBUCK CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, August 06, 2025

Corrective Action Required:

- | | | |
|---|------|--|
| 2 | Misc | - Seal penetration exterior at cat5 by electrical meter |
| | | - Land sewer trace wire to grade |
| | | - provide splash pads at down spout |
| | | - Change receptacle at water heater to single and mark non GFCI |
| | | - Provide security screws at all exterior doors per city ordinance |
| | | - Seal exterior rim board at A/C intake/ exhaust |

Comments: